



## Sample Centre Facilities Audit

### Beam House

Activity	Access Details	Centre specific Physical Requirements
<ul style="list-style-type: none"> <li>Accommodation</li> </ul>	<ul style="list-style-type: none"> <li>The Old Block has guest rooms on the first and second floors. These are accessible only by stairs; the main stairs are narrow and curved.</li> <li>The emergency stairs at the back are much wider and straight.</li> <li>There is a wide and sloped doorway for access to the house</li> <li>The new block (3 years old) has accommodation on the ground floor</li> <li>It has a disabled access room that is usually used for teachers unless needed by a guest.</li> <li>It is a single en suite room</li> </ul>	<ul style="list-style-type: none"> <li>The Disabled access room has purpose built en suite facilities, including support rails and shower seat.</li> </ul>
<ul style="list-style-type: none"> <li>Toilet / Shower facilities</li> </ul>	<ul style="list-style-type: none"> <li>Accessible shower and toilet in accessible room on ground floor.</li> <li>All other toilets and showers on accommodation floors</li> </ul>	<ul style="list-style-type: none"> <li>Challenge Course Showers on ground floor. There are steps to access, but centre has ramps to use on them.</li> </ul>
<ul style="list-style-type: none"> <li>Dining area</li> </ul>	<ul style="list-style-type: none"> <li>Entrance through double doors from decked area made level with doorway</li> <li>Exit through double doors into ground floor New Block corridor</li> </ul>	<ul style="list-style-type: none"> <li>Laminated wooden style flooring.</li> <li>Round tables – 75cm high. Very tight spaces around tables. Would need to be seated at a table at edge of dining room.</li> <li>Servery – 81cm high. Plates are carried, no trays.</li> <li>Very busy and crowded area.</li> </ul>
<ul style="list-style-type: none"> <li>Social areas (Please specify)</li> </ul>	<ul style="list-style-type: none"> <li>Basket ball court situated outside – smooth tarmac surface</li> <li>Top field – approx 300m from main building, uneven grassy surface</li> <li>Tuck shop/disco hall building – approx 25m from main building.</li> </ul>	<ul style="list-style-type: none"> <li>Sloped for easy access to basketball court</li> <li>To get from court around house is all gravel drive – to go through house requires going up and down three steps in concrete corridor.</li> <li>Access up inclined drive way</li> <li>Ramp available for access up step in room</li> <li>Tuckshop with counter service – about 1m high</li> </ul>
<ul style="list-style-type: none"> <li>First aid Facility</li> </ul>	<ul style="list-style-type: none"> <li>First Aid point at Main office</li> <li>Kits made up for mobile FA at any place on site</li> </ul>	<ul style="list-style-type: none"> <li>Access through office door – 73cm wide</li> <li>The easy access room can be operated as a first aid room as long as it is not occupied, this room has a single bed and en suite facilities</li> </ul>